


B.E.G. LUXOMAT®

Operating and mounting instruction B.E.G. motion detector Indoor 180-R-11-48V AC/DC



Thank you for purchasing the motion detector. You have opted for a quality product from the **B.E.G.** range and for one which has been manufactured, tested, packaged and despatched with the utmost care. Please read the information contained in these directions before commencing assembly. We reserve the right to make any technical adjustments which are in the interests of product-improvement.

As long as motions are detected the connected lights remain switched on. When there is no more motion the light is switched off after the pre-adjusted time. 3 sec. only after switching off the **LUXOMAT®** Indoor 180 can be activated again by motions.

The **LUXOMAT®** Indoor 180 is equipped with a semi-ball size-fresnel lens which gives a semicircular detection field (horizontally appr. 180°, vertically appr. 60°). With regard to the recommend fixing height of 1.10 - 2.20m and to a motion transversally to the lens segments the radius of the detection field is up to 10m.

Acoustic function

As long as the acoustic sensor receives noises e.g. by speech or music the **LUXOMAT®** Indoor 180 remains switched-on even when there are no more motions – the light stays on. Every noise and every motion retriggers the unit again for the period of preselected time. Unless there is no more motion and no more noise the **LUXOMAT®** Indoor 180 switches the light off automatically. Immediately thereafter the Indoor 180 can be switched on again e.g. by calling when this is been done within a period of 8 sec. However if the Indoor 180 not been activated for a longer period, then the unit can be retriggered only by a motion. This combination protects the unit to be switched on by unwanted noises.

2. Prior to installation:

Before installation the following aspects have to be considered:

- The **LUXOMAT®** Indoor 180 is designed for the installation in standard switch flushmount boxes. The recommended fixing height is 1.10 to 2.20m.
- Not more than eight **LUXOMAT®** Indoor 180 can be switched into parallel, in order to avoid potential fault switchings.
- The connected load must not exceed the following values: **11-48V AC/DC**
- There must be no obstacles in the view of the motion detector, since infrared rays cannot penetrate solid materials.
- The **LUXOMAT®** Indoor 180 is an automatic light switch which cannot be used for intrusion applications.

Selection of fixing place:

The optical system of the **LUXOMAT®** Indoor 180 is designed for fixing heights of 1.10 to 2.20m. A typical application is the replacement of a wall switch in appr. 1.10m height or for room surveillance in 2.20m height (pt. 6).

Additionally to the horizontal detection plane the Indoor 180 has a vertical detection plane which detects also movements underneath the motion detector. The maximum range is 10m, independently of fixing height.

The range cannot be adjusted electronically or manually, instead unwanted detection areas have to be eliminated by adhesive tape that must be put on the corresponding lens segments.

Frontal approach

To get a satisfying functioning of the motion detector the following typical property of infrared motion detectors must be considered:


Motion detectors are most sensitive when motions are across the detection zones. In case of a frontal approach the sensitivity and hence the range is considerably reduced (pt. 6).

3. Installation


The detector can be installed in conventional installation sockets. Installation should be made to a wall with a height of 1.10 to 2.20m.

For the combination with switches of leading manufacturers the enclosed additional blinds can be used.

Mounting diagram



- **Clear mains' voltage!**
- Connect sensor part **(A)** according to the regulations and as shown in the wiring diagrams (pt. 5).
- Depending upon the concealed housing, fasten at the top and the bottom or left and right using the enclosed screws **(B)**.
- Additionally to the horizontal detection plane the Indoor 180 has a vertical detection plane which detects also movements underneath the motion detector. In order to prevent detection within the vertical range of coverage, apply cover **(C)**.
- Next introduce and fasten the blinds **(D)** and the covering-cap **(E)**.
- Switch on mains' voltage. The **LUXOMAT®** Indoor 180 is ready for use after having completed a **self-checking cycle of about 60 seconds**.
- Settings of the operating time and twilight value.
- Mount covering-cap **(F)**.
- The covering-cap **(F)** can be removed as shown in the drawing.



Type	Part-No.
Indoor 180-R-11-48V-3A, fully fitted, pure white (3A-Version)	92621
Sensorinsert for Indoor 180-R-11-48V-3A (3A-Version)	92666
Sensorinsert for Indoor 180-R-11-48V-RR (version with Reed-relay)	92667
Covering IP20, pure white	92630
Covering IP20, traffic white	92631
Covering IP20, cream	92632
Covering IP20, silver	92633
Covering IP20, anthracite	92634
Covering IP54, pure white	92139

1. Function

With the **LUXOMAT®** Indoor 180 you acquired a **B.E.G.**-motion detector for flush mounting in indoor and outdoor applications. The **LUXOMAT®** Indoor 180 is an automatic switching device which operates on the principle of infrared technology. It continuously measures the ambient temperature and the ambient lightlevel and compares it with the infrared radiation emitted from any moving form which enters its detection zone. Any differential results in automatic switching, provided the lightlevel is beyond a preset lightlevel. Contrary to other motion detectors which reacts to moving heatsources only, with the **LUXOMAT®** Indoor 180 you will not be left in the dark unless there is no more motion because through a combination with an acoustic sensor it reacts additionally to noises.

Detecting movement

The sensitivity of **LUXOMAT®** Indoor 180 has been designed to detect the human form including of course children and it is therefore possible that some animals, principally large dogs, will also switch the system. This is unavoidable but, in most instances, offers an advantage as unwanted animals are frightened away by sudden lighting.

For outdoor installations additionally the IP54-accessory-fixing-set has to be mounted (Part nr. 92139).

4. Adjustment of twilight-switch and acoustic-sensor

4.1 Lux-level setting (Photocell)

The lux-level can be set between 5 and 2000 Lux


☾ Night operation

☀ Day and night operation

4.2 Switch-off delay time

The switch-off delay time can be set from ca. 15 sec. to 16 min.

(When setting into operation it is recommended to use the shortest timesetting for convenient testing of range and noise sensitivity (pt. 4.3).)




4.3 Noise sensitivity

Fully counterclockwise means highest sensitivity. Fully clockwise means noise detector switched off. Intermediate values to be adjusted accordingly to local conditions. Functioning of the noise detector will be indicated by a LED located behind the lens.

Lighting of the LED means the noise detector is functioning and triggers the timer again.

5. Wiring diagrams:

Standard mode with 1-channel 11-48V motion detectors




optional

T1 = NO button for semi-automatic mode

Slave for enlargement of detection area

6. Detection area



- 1 Walking towards
- 2 Walking across

7. Technical data

- Supply voltage 11-48V AC/DC
- Detection angle 180° horizontally
ca. 60° vertically

• Switching power

Indoor 180-R-11-48V-3A (Version 3 A):

- 3A, $\cos\phi=1$

Indoor 180-R-11-48V-RR (Version with reed relay):

- 100 mA, $\cos\phi=1$,
for extra low-noise switching

- Range (1.10 - 2.20 m mounting height)
max. 10 m for lateral walking
appr. 3 m for frontal walking

- Timesettings pulse, 15 sec. - 16 min.
- Photo electric switch ca. 5 - 2000 Lux

- Dimensions L x W 87 x 87 mm
- Depth 36 mm

- Protection / class IP20, II

- Cabinet material Polycarbonate

CE Declaration of Conformity: The product complies with the low voltage recommendation 2006/95/EC and the EMV recommendation 2004/108/EC.

8. Electromagnetic Compliance (EMV)

When positioned within the direct vicinity of high powered radio transmitting equipment (e.g. portable phones, H.A.M., taxi, police, fire, ambulance, radio operators etc.) false activation switching may be experienced. However, this influence will not damage the sensor electronics.

The automatic switching of the sensor will be switched off as soon as the source of radio interference stops transmitting.

9. Trouble shooting – Practical hints

1. Lamp does not light up

- Tungsten halogen lamp defective
Replace tungsten halogen lamp
- No mains connection
Check connection by qualified electrician
- Incorrect setting of lux level
Correct setting of lux level
- Unit mounted too high
Mount at recommended height
- PIR detector lens obstructed by dirt or other objects
Clean lens or remove objects
- Main fuse defective
Check or replace by qualified electrician

2. Delayed lamp activation

- Mounted too high
Mount at height stated in specification (1.10 - 2.20 m)
- Direct line of approach
Re-direct walking so that the approach is not frontally

3. Lamp stays on continuously

- Continual thermal activity detected ie. extractor fan, central heating ducts
Check for any activity which could cause unit detection to be maintained
- Delay time set too high
Reduce time delay
Check ambient noise-level, if necessary switch off noise-sources

4. Limitation of range (not up to the minimum specification)

- Mounted too high
Correct mounting height
- Temperature difference between ambient temperature and source of heat too small
No improvement possible
- Direction of movement aimed directly at lens of motion detector
Move laterally to detector